



Ref. Certif. No.

ES1885-M1-AENOR**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

IGNITOR FOR DISCHARGE LAMPS

Name and address of the applicant

ELECTROSTART JSCo
2 Republica Blvd.
3540 Vurshets (Bulgaria)

Name and address of the manufacturer

SAME AS ABOVE

Name and address of the factory

SAME AS ABOVE

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

220-240 V~; 50/60 Hz; HPSV: 1 x 600-1000 W without rectifying effect; MH: 1 x 1000 W; 3,5 / 5 kV; To build-in; tc = 65 °C; tc+X = 105 °C; ta = -30 to +65 °C; 10,3 A max.; terminals connection

Trademark (if any)

ELECTROSTART

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

ZX 1000

Additional information (if necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60927:2007
IEC 60927:2007/AMD1:2013
IEC 61347-1:2015
IEC 61347-1:2015/AMD1:2017
IEC 61347-2-1:2000
IEC 61347-2-1:2000/AMD1:2005
IEC 61347-2-1:2000/AMD2:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

2015090469B1, 2015090470B1, 2021100555B1

This CB Test Certificate is issued by the National Certification Body

AENOR INTERNACIONAL S.A.U.
CI Génova, 6
ES-28004 MADRID (SPAIN)

Date: 2022-01-03

Signature: Rafael GARCÍA MEIRO
Chief Executive Officer