


CENTER FOR TESTING AND EUROPEAN CERTIFICATION LTD

2, Industrialna Str., Stara Zagora, 6000, Bulgaria,
 Tel.: +359 42 630476; +359 42 620368; Fax: +359 42 602377;
 www.ctec-sz.com e-mail: ctec@ctec-sz.com


LABORATORY FOR TESTING OF MACHINERY, EQUIPMENT AND DEVICES

Certificate of accreditation № 101 ЛИ / 22.11.2019, valid until: 26.11.2022
 Issued by EA BAS, in accordance with the requirements of BDS EN ISO/IEC 17025:2018



TEST REPORT

№ 2e-21-623 / 28.09.2021

OBJECT TO BE TESTED: Electric and electronic equipment, appliances, devices. Luminaries.
 Lighting fixture, Item: LED Glow Economy 40W 120lm/W D66 External 4000K
 Model representative of serie: LED Glow Economy (see page 2)
(name of object to be tested , type, model, quantity, type and other)

APPLICANT FOR TEST: "Electrostart" JSCo. 3540 Varshets, 2 Republika Blvd.,
 Tel.: +359 2 400 7011, fax: + 359 2 400 7012;
 Application № 623/ 28.07.2021
(name of the firm – applicant, address, telephone, number and date of the test application)

METHOD OF TEST : BDS EN 60598-1:15+AC:15+AC:16+A1:18 Luminaires - Part 1: General requirements and tests
(number and name of the standards)

DATE OF ACCEPTANCE IN THE TEST LABORATORY: 28.07.2021

CODE OF THE OBJECT: 1 piece, ref.№ 981240120042158, year of production 2021

MANUFACTURER: "Electrostart" JSCo. 3540 Varshets, 2 Republika Blvd.,
 Tel.: +359 2 400 7011, fax: + 359 2 400 7012
(firm, trade mark, address)

DECLARED TECHNICAL DATA: Rated voltage – 220-240 V AC
 Rated frequency – 50/60 Hz
 Rated power – 40 W
 Class II
 Maximum ambient temperature $t_a=40^{\circ}\text{C}$
 Degree of protection IP40 Below

ELECTRONIC CONTROLGEAR: 40W LED Driver 1000 mA, ref.№ 170200000000112 Electrostart

TECHNICAL REQUIREMENTS: BDS EN 60598-1:2015+AC:2015+AC:2016+A1:2018 Luminaires –
 Part 1: General requirements and tests
 BDS EN 60598-2-2:2012 Luminaires - Part 2-2: Particular requirements –
 Recessed luminaires

DATE OF TEST PERFORMANCE: 28.07.2021 – 28.09.2021

THE HEAD OF LABORATORY:
 / T. Hristov /



*The results showed in present certificate concern tested sample only
 The certificate could be reproduced as a whole only and after written permission of the
 laboratory*



**LABORATORY FOR TESTING OF MACHINERY, EQUIPMENT AND DEVICES
CENTER FOR TESTING AND EUROPEAN CERTIFICATION LTD – Stara Zagora**

Page 2 of 8

Test report : № 2e-21-623 / 28.09.2021

Serie: LED Glow Economy

LED Glow Economy 36W D66 100lm/W 3000K	LED Glow Economy 36W D312 100lm/W 3000K
LED Glow Economy 36W D66 100lm/W 4000K	LED Glow Economy 36W D312 100lm/W 4000K
LED Glow Economy 36W D66 100lm/W 6500K	LED Glow Economy 36W D312 100lm/W 6500K
LED Glow Economy 36W D66 120lm/W 3000K	LED Glow Economy 36W D312 120lm/W 3000K
LED Glow Economy 36W D66 120lm/W 4000K	LED Glow Economy 36W D312 120lm/W 4000K
LED Glow Economy 36W D66 120lm/W 6500K	LED Glow Economy 36W D312 120lm/W 6500K
LED Glow Economy 40W D66 100lm/W 3000K	LED Glow Economy 40W D312 100lm/W 3000K
LED Glow Economy 40W D66 100lm/W 4000K	LED Glow Economy 40W D312 100lm/W 4000K
LED Glow Economy 40W D66 100lm/W 6500K	LED Glow Economy 40W D312 100lm/W 6500K
LED Glow Economy 40W D66 120lm/W 3000K	LED Glow Economy 40W D312 120lm/W 3000K
LED Glow Economy 40W D66 120lm/W 4000K	LED Glow Economy 40W D312 120lm/W 4000K
LED Glow Economy 40W D66 120lm/W 6500K	LED Glow Economy 40W D312 120lm/W 6500K
LED Glow Economy 36W 100lm/W D66 UGR 3000K	LED Glow Economy 36W D312 100lm/W UGR 3000K
LED Glow Economy 36W 100lm/W D66 UGR 4000K	LED Glow Economy 36W D312 100lm/W UGR 4000K
LED Glow Economy 36W 100lm/W D66 UGR 6500K	LED Glow Economy 36W D312 100lm/W UGR 6500K
LED Glow Economy 40W 120lm/W D66 UGR 3000K	LED Glow Economy 36W D312 120lm/W UGR 3000K
LED Glow Economy 36W 120lm/W D66 UGR 4000K	LED Glow Economy 36W D312 120lm/W UGR 4000K
LED Glow Economy 40W 120lm/W D66 UGR 6500K	LED Glow Economy 36W D312 120lm/W UGR 6500K
	LED Glow Economy 40W D312 100lm/W UGR 3000K
	LED Glow Economy 40W D312 100lm/W UGR 4000K
	LED Glow Economy 40W D312 100lm/W UGR 6500K
	LED Glow Economy 40W D312 120lm/W UGR 3000K
	LED Glow Economy 40W D312 120lm/W UGR 4000K
	LED Glow Economy 40W D312 120lm/W UGR 6500K

*The results showed in present certificate concern tested sample only
The certificate could be reproduced as a whole only and after written permission of the laboratory*





LABORATORY FOR TESTING OF MACHINERY, EQUIPMENT AND DEVICES
 CENTER FOR TESTING AND EUROPEAN CERTIFICATION LTD – STARA ZAGORA

Copy of identification table and/or photo of tested object



Electrostart
WORLD OF LIGHT

Item: **LED Glow Economy 40W 120lm/W D66 External 4000K**
 Model: 981240120042158
 Power: 40W
 Color temperature: 4000K
 Input voltage: 220-240VAC
 Frequency: 50/60 Hz
 Luminous flux: 4 800 lm
 PF: ≥ 0.90
 Ra: > 80
 ta: -10...+40°
 Dimensions: 595x595x35 mm
 Body: Aluminium + PS
 Connected with LED converter 1000mA

RoHS
 IP40 Below
 CE
 Made in BG/EU

L • 220-240VAC 0.5...9.5 mm
 PRI 30/60Hz
 N • 1.0 95C
40W LED Driver 1000mA
 CONSTANT CURRENT
 Electronic driver for Light Emitting Diodes

Electrostart
 Ref. № 170200000000112
 tc: 75°C ta: -15...+45°C

EN62384
 SELV
 MADE IN BG/EU IP20

1000mA → LED
 32-40VDC
 Ultra < 40VDC
 40W → LED

The results showed in present certificate concern tested sample only
 The certificate could be reproduced as a whole only and after written permission of the laboratory





**LABORATORY FOR TESTING OF MACHINERY, EQUIPMENT AND DEVICES
CENTER FOR TESTING AND EUROPEAN CERTIFICATION LTD – STARA ZAGORA**

RESULTS OF TESTING:

Page 4 of 8 **BDS EN 60598-1:15+AC:15+AC:16+A1:18** Test report : № 2e-21-623 / 28.09.2021

Nº	Factor name	Units	Standard method	Nº of sample	Test results (indetermination)	Factor volume and tolerance	Test conditions
1.	Mechanical strength:	-	cl. 4.13	623	-	cl. 4.13	
1.1	Impact tests from spring hammer: - fragile parts - other parts	N.m N.m	cl. 4.13.1	623 623	Withstand 0,20 0,35	cl. 4.13.1 Table 4.3 0,20 0,35	-
2.	Resistance to force and torque:	-	cl. 4.13	623	-	cl. 4.13	
2.1	Mechanical load: - four times the weight - torque 2,5 Nm	min N N.m	cl. 4.14.1	623 623 623	-	cl. 4.14.1	-
2.2	Straight test finger	N	cl. 4.13.3	623	withstand 30	cl. 4.13.3 30	-
2.3	Lampholder	N	cl. 4.4.4 and cl.4.12.4	623	-	cl. 4.4.4	1 min
2.4	Screws	N.m	cl.4.12	623	withstand 1,2 N.m for M4	cl.4.12 1,2 N.m	-
3.	Creepage distances and clearances:	-	cl. 11.2.1	623	-	cl. 11.2	-
3.1	Creepage distances for a.c. (50 Hz) sinusoidal voltages ≤ 250 V	mm mm mm	cl. 11.2.1	623 623 623	> 5 > 6 > 8	Table11.1 Basic insulation ≥ 1,5 Suppl. insulation ≥ 2,5 Reinforced insulation ≥ 5	-
3.2	Clearances for a.c. (50 Hz) sinusoidal voltages ≤ 250 V	mm mm mm	cl. 11.2.1	623 623 623	> 4 > 5 > 7	Table11.1 Basic insulation ≥ 1,5 Suppl. insulation ≥ 1,5 Reinforced insulation ≥ 3	-

*The results showed in present certificate concern tested sample only
The certificate could be reproduced as a whole only and after written permission of the laboratory*





**LABORATORY FOR TESTING OF MACHINERY, EQUIPMENT AND DEVICES
CENTER FOR TESTING AND EUROPEAN CERTIFICATION LTD – STARA ZAGORA**

Page 5 of 8 BDS EN 60598-1:15+AC:15+AC:16+A1:18 Test report : № 2e-21-623 / 28.09.2021

№	Factor name	Units	Standard method	№ of sample	Test results (indetermination)	Factor volume and tolerance	Test conditions
4.	Provision for earthing:	-	cl. 7.2	623	-	cl. 7.2	-
4.1	Metal parts in contact with supporting surface	Ω	cl. 7.2.3	623	-	cl. 7.2.1 ≤ 0,5	10A 1 min
5.	Resistance to tensile and torsional for power cords:	-	cl. 5.2	623	-	cl. 5.2	-
5.1	Cord anchorage - pull - torque - displacement	N N.m mm	cl. 5.2.10.3	623 623 623	- - -	cl. 5.2.10.1 Table 5.2	-
6.	Protection against electric shock	N	cl. 8.2.5	623	withstand 10	cl. 8.2.1÷ cl. 8.2.4 10	-
7.	Protection against residual voltages	V	cl. 8.2.7	623	0	cl. 8.2.7 < 50	1 min
8.	Heating / Temperature /	-	cl. 12	623	-	cl. 12	-
8.1	Normal operation Case of controlgear Insulation of internal wiring Terminal blocks Mounting surface	°C °C °C °C	cl. 12.4.1	623 623 623 623	Maximum temperature with LED P _n = 40 W 58 49 51 46	cl. 12.4.2 Table 12.1 ; 12.2 ≤ 75 ≤ 90 ≤ 120 ≤ 90	t=t _a =40°C U=1,06U _n =254,4 V
8.2	Abnormal operation Mounting surface	°C	cl. 12.5.1	623 623	- 46	cl. 12.5.2 Table 12.3 ≤ 130	t=t _a =40°C U=1,1 U _n =254,4 V
9.	Endurance test	h	cl. 12.3.1	623	withstand 240	cl. 12.3.2 240	t= t _a +10=50°C U=1,1 U _n =264 V
10.	Degrees of protection provided by enclosures (IP code)	-	cl. 9.2	623	withstand IP 40 below	≥ IP 20	-
10.1	Protection against penetration of solid objects and dust - below	-	cl. 9.2.0	623	withstand IP 4X	IP 4X	1 N
10.2	Protection against penetration of harmful water	-	τ. 9.2.0	623	IP X0	IP X0	-
11.	Humidity resistance	h	cl. 9.3.1	623	withstand 48 see cl. 12 , cl.13 of test report	cl. 9.3 48	Rh=95% t=25°C

*The results showed in present certificate concern tested sample only
The certificate could be reproduced as a whole only and after written permission of the laboratory*





**LABORATORY FOR TESTING OF MACHINERY, EQUIPMENT AND DEVICES
CENTER FOR TESTING AND EUROPEAN CERTIFICATION LTD – STARA ZAGORA**

Page 6 of 8 **BDS EN 60598-1:15+AC:15+AC:16+A1:18** Test report : № 2e-21-623 / 28.09.2021

№	Factor name	Units	Standard method	№ of sample	Test results (indetermination)	Factor volume and tolerance	Test conditions
---	-------------	-------	-----------------	-------------	--------------------------------	-----------------------------	-----------------

12.	Insulation resistance:	-	cl. 10.2.1	623	-	cl. 10.2.1 Table 10.1	-
12.1	Between current-carrying parts of different polarity	MΩ	cl. 10.2.1	623	-	R > 2	1 min , 500 V
12.2	Between life parts and mounting surface	MΩ	cl. 10.2.1	623	R > 999	R > 2	1 min , 500 V
12.3	Between life parts and metal parts of luminaire	MΩ	cl. 10.2.1	623	R > 999	R > 2	1 min , 500 V
12.4	Basic insulation	MΩ	cl. 10.2.1	623	R > 999	R > 2	1 min , 500 V
12.5	Additional insulation	MΩ	cl. 10.2.1	623	R > 999	R > 3	1 min , 500 V
12.6	Double or reinforced insulation	MΩ	cl. 10.2.1	623	R > 999	R > 4	1 min , 500 V

13.	Dielectric strenght of insulation :	-	cl. 10.2.2	623	-	cl. 10.2.2 Table 10.2	-
13.1	Between current-carrying parts of different polarity	V	cl. 10.2.2	623	-	U(perf.) = 1480	1 min , 50 Hz
13.2	Between life parts and mounting surface	V	cl. 10.2.2	623	withstand U = 2960	U(perf.) = 1480	1 min , 50 Hz
13.3	Between life parts and metal parts of luminaire	V	cl. 10.2.2	623	withstand U = 2960	U(perf.) = 1480	1 min , 50 Hz
13.4	Basic insulation	V	cl. 10.2.2	623	withstand U = 1480	U(perf.) = 1480	1 min , 50 Hz
13.5	Additional insulation	V	cl. 10.2.2	623	withstand U = 1480	U(perf.) = 1480	1 min , 50 Hz
13.6	Double or reinforced insulation	V	cl. 10.2.2	623	withstand U = 2960	U(perf.) = 2960	1 min , 50 Hz

*The results showed in present certificate concern tested sample only
The certificate could be reproduced as a whole only and after written permission of the laboratory*




**LABORATORY FOR TESTING OF MACHINERY, EQUIPMENT AND DEVICES
CENTER FOR TESTING AND EUROPEAN CERTIFICATION LTD – STARA ZAGORA**
Page 7 of 8 BDS EN 60598-1:15+AC:15+AC:16+A1:18 Test report : № 2e-21-623 / 28.09.2021

№	Factor name	Units	Standard method	№ of sample	Test results (indetermination)	Factor volume and tolerance	Test conditions
14.	Touch current, Protective conductor current	mA	cl. 10.3	623	0,02	cl. 10.3 ≤ 0,7	-
		mA		623	-	≤ 3,5	
15.	Resistance to heat /Resistance to abnormal heat – Ball pressure test method/	mm	cl. 13.2.1	623	0,8	cl. 13.2 ≤ 2	t=125 °C 60 min
16.	Resistance to flame and ignition	-	cl. 13.3	623	-	cl. 13.3	-
16.1	Needle-flame test method	s	cl. 13.3.1	623	0	cl. 13.3.1 ≤ 30	-
16.2	Glow-wire flammability test method	°C	cl. 13.3.2	623	no ignition at 650 °C	cl. 13.3.2 glow-wire (650 ± 10) °C for 30s	-
17.	Tracking test	V	cl. 13.4	623	withstand 175 V without ignition and leakage currents > 0,5 A	cl. 13.4 175	50 drops
18.	Peak pulse voltage	V	cl. 4.4.5	623	-	cl. 4.4.5 ≤ 5000 V	-

*The results showed in present certificate concern tested sample only
The certificate could be reproduced as a whole only and after written permission of the laboratory*





**LABORATORY FOR TESTING OF MACHINERY, EQUIPMENT AND DEVICES
CENTER FOR TESTING AND EUROPEAN CERTIFICATION LTD – STARA ZAGORA**

Page 8 of 8

Test report : № 2e-21-623 / 28.09.2021

Used technical equipments:

Nº	Designation	Type	Manufacturer	Identification Nº	Date of last calibration
1.	Appliance multitester	CA6160	CHAUVIN ARNOUX France	16010173	20.03.2020
2.	Digital multimeter	UNIGOR 390	LEM- Austria	PI 3288	20.03.2020
3.	Microhmmeter	C.A 6250	CHAUVIN ARNOUX France	1811ST030731A	20.03.2020
4.	Climatic chamber	Alpha 990H	Design Environmental England	A3793	-
5.	Multi channel termoneter	MT100TD-16	Bulgaria	0418/2009	09.06.2020
6.	Digital gauge	-	China	090	23.10.2019
7.	Impact spring hammer tester	-	Bulgaria	011	21.07.2020
8.	Termometer-higrometer	177-H1	TESTO Germany	01320300/902	29.04.2021
9.	Testing finger with articulation	-	Bulgaria	Nº 006	21.07.2020
10.	Testing wire (ø1mm;L=100mm)	-	HI-HMC, Bulgaria	Nº 066	21.07.2020

TEST PERFORMER: 1.....

/ T. Hristov /

2.....

/ D. Chavalinov /

HEAD OF THE LABORATORY:.....

/ T. Hristov /



***The results showed in present certificate concern tested sample only
The certificate could be reproduced as a whole only and after written permission of the laboratory***